warringtonfire
Proud to be part of element

Approved Body No. 1121

Certificate of Constancy of Performance

1121-CPR-UK- ABB7501

In compliance with Construction Products Regulation 2011 (retained EU law EUR 2011/305) as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, this certificate applies to the Construction Product:

NET2 Paxlock Pro-Euro, Paxlock Pro-Euro & Paxton10 Paxlock Pro-Euro Emergency Exit Devices

Intended use:- **For use on single leaf escape route doors, including fire resisting / smoke control doors**

Essential characteristics	Performance	Designated standard
Mechanical Test Evidence: 4788528484, 4788985602, 4789252081 & WIL 509624 Fire Test Evidence: 4788771531.1.1, 17-002998-PR01, 17-002999-PR02 & WF 375539		
Clause 4.2.1 Ability t Release (for doors on escape routes) Release function Lever handle Single doorset Souble doorset Exposed edges and corners Lever handle installation Operating element projection Operating element face (Lever handle) Lever handle operating gap Test rod Accessible gap Door free movement Top vertical bolt Keepers Keepers dimensions Door mass and dimensions Door mass and dimensions Outside access device Release forces Security requirement	 < 1 sec Pass Pass NPD Pass X >120mm & Z < 150mm W< 100mm V> 18mm / free end U> 40mm / W < 100mm, a <30° Pass Pass Pass Pass NPD Pass NPD Door mass ≤ 200 KG, door height ≤ 2500mm, door width≤ 1300mm Pass Type A < 70N Grade 3	EN 179:2008
Clause 4.2.1 Durability of ability to release against aging and degradation (for doors on escape routes) Corrosion resistance Temperature range Lubrication Re-engagement force Durability Abuse resistance- lever handle Final examination	 Grade 3 : 96 Hours Operating forces at -10 C° And at + 60 C° < 50% in excess of the operating forces at +20 C° Lubrication every 20 000 cycles < 50 N Grade 7: 200 000 cycles 500 N & 1000N Type A < 70 N	

This certificate is the property of Warringtonfire Testing and Certification Limited. Registered in England and Wales
Registered Office: 3rd Floor, Davidson Building, 5 Southampton Street, London, WC2E 7HA. Company Registration No: 11371436

Approved Body No. 1121

Certificate of Constancy of Performance

1121-CPR-UK- ABB7501

Essential characteristics	Performance	Designated standard
Clause 4.2.1 Self closing ability C (for fire/smoke doors on escape routes) Re-engagement force	< 50 N	EN 179:2008
Clause 4.2.1 Durability of self closing ability C against aging and degradation (for fire/smoke doors on escape routes) Durability Re-engagement force	Grade 7: 2000 000 cycles < 50 N	
Clause 4.2.1 resistance to fire E (integrity and I (insulation) (for fire doors on escape routes Suitability of panic exit devices for use on fire resisting doorsets assemblies- Additional requirements	Grade B : Suitable for use on fire/smoke single door assemblies.	
Clause 4.1.25 Control of Dangerous substances	If a reference to dangerous substances is added in the table ZA.1, the following claim is suggested: Pass: the materials in the device do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations.	

REFERENCES	ITEMS	DESCRIPTION
NET2 PaxLock 900-100 & 900-200	Net 2 Paxlock Pro - Euro	Handle Set complete with fixings
Paxton10 PaxLock PR 010-602 & 010-603	Paxton10 PaxLock Pro	Handle Set complete with fixings
Paxlock Pro-Euro 900-600 & 900-610	Paxlock Pro-Euro	Handle Set complete with fixings
901-015	Net2 Paxlock Pro – Euro, EN179 Kit	ASSA ABLOY / UNION JHD72ESL-R-SS60 and strike plate, complete with fixings and Z80-mk090 Split Spindle

NET2 Paxlock Pro-Euro			
900-100BL	NET2 Paxlock Pro-Euro, External, Black		
900-100WT	NET2 Paxlock Pro-Euro, External, White		
900-200BL	NET2 Paxlock Pro-Euro, Internal, Black		
900-200WT	NET2 Paxlock Pro-Euro, Internal, White		
Paxton10 Paxlock Pro-Euro		**Paxlock Pro-Euro**	
010-602BL	Paxton10 Paxlock Pro-Euro, External, Black	900-600WT	PaxLock Pro-Euro, Internal, White
010-602WT	Paxton10 Paxlock Pro-Euro, External, White	900-600BL	PaxLock Pro-Euro, Internal, Black
010-603BL	Paxton10 Paxlock Pro-Euro, Internal, Black	900-610WT	PaxLock Pro-Euro, External, White
010-603WT	Paxton10 Paxlock Pro-Euro, Internal, White	900-610BL	PaxLock Pro-Euro, External, Black

This certificate is the property of Warringtonfire Testing and Certification Limited. Registered in England and Wales
Registered Office: 3rd Floor, Davidson Building, 5 Southampton Street, London, WC2E 7HA. Company Registration No: 11371436

warringtonfire
Proud to be part of element

Approved Body No. 1121

Certificate of Constancy of Performance

1121-CPR-UK- ABB7501

Placed on the market under the name of:

Paxton Access Ltd
Paxton House
Home Farm Road
Brighton
East Sussex
BN1 9HU
United Kingdom

and produced in the manufacturing plant

E/414

This is coded format and the information is held by the Approved Body

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 179: 2008

Under System 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **07/07/2021** and re-issued on **08/06/2023** and will remain valid as long as neither the designated standard, the Construction Product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Approved Product Certification Body.

UKCA certificate valid to: **06/07/2024**

UKAS PRODUCT CERTIFICATION

0087

Paul Duggan
Certification Manager

Warringtonfire Testing and Certification Limited
Suite 302, The Genesis Centre, Birchwood, Warrington, WA3 7BH, UK

This certificate is the property of Warringtonfire Testing and Certification Limited. Registered in England and Wales
Registered Office: 3rd Floor, Davidson Building, 5 Southampton Street, London, WC2E 7HA. Company Registration No: 11371436